

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-C0002

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

Warrior Doors single leaf doorset

(For full product details and conditions of use as defined by the ETA, refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Warrior Doors
Unit 4, Kings Road Industrial Estate
Birmingham
West Midlands
B11 2AX
United Kingdom

Warrior Doors
Unit 4, Kings Road Industrial Estate
Birmingham
West Midlands
B11 2AX
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

BRE Test Report No. P108951-1000 Issue 1


and

EU Harmonised Standard BS EN 14351-1:2006+A1:2010

under system 1 for the performance set out in the EU Harmonised Standard, and that the Factory Production Control process conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 18 July 2017 and will remain valid as long as none of a) the BRE Test Report, b) the EU Harmonised Standard BS EN 14351-1:2006+A1:2010, c) the construction product, d) the AVCP system nor e) the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



David Gall, Associate Director,
On behalf of BRE Global Limited

Date of first issue: 18 July 2017

Date of issue: 18 July 2017

Issue number: 1

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-C0002**Warrior Doors single leaf doorset**

Single leaf doorset

Description of the product

This certificate related to Warrior Doors single leaf doorset with magnetic locks with the following attributes:

- Frame:** 304 Grade Stainless steel
Glazing: Anti-bandit 11.5 mm laminated glass
Seals: Weather seals around perimeter of joints and glazing
Hardware: Electronic magnetic locks
Drainage: No drainage
Fixings: Fixings to any sub-frames for testing not visible
Dimensions: 2200 mm high x 1350 mm wide. Area: 2.97 m²
Overall length of opening joint = 6.34 m

CE marking method(s) used and levels/classes of performance of the product

Within BS EN 14351-1:2006+A1:2010 the following test methods were used and classifications achieved:

Test Method	Classification Achieved
Air permeability: BS EN 12207:2015	Class 1
Watertightness: BS EN 12208:2000	Class 2A
Resistance to wind load: BS EN 12210:2016	Class A2

Additional manufacturing plants covered by this certificate

None

David Gall, Associate Director,
On behalf of BRE Global Limited

Date of first issue: 18 July 2017

Date of issue: 18 July 2017

Issue number: 1

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.